## GREEN LABEL PLUS

## **INDOOR AIR QUALITY TESTING PROGRAM**

THIS CERTIFIES THAT Shaw Industries, Inc.

Shaw Residential, Anderson Tuftex, Shaw Contract, Shaw Hospitality, Patcraft, Philadelphia Commercial 616 E Walnut Ave, Dalton, GA 30721, United States

HAS MET THE REQUIREMENTS OF THE CARPET AND RUG INSTITUTE'S GREEN LABEL PLUS PROGRAM FOR CATEGORY:

## A-3 Floor Adhesive for Vinyl Backs

Adhesive Applied in Mass Per Surface Area: 8.4 g of product per 0.0361 m<sup>2</sup>

Private Office Range of Total VOCs: 0.5 mg/m³ or less

School Classroom Range of Total VOCs: 0.5 mg/m³ or less

Type of Product: Single Part Wet Adhesive

Description: Shaw MS Resilient Adhesive and Shaw DP99

Russ DeLozier, President The Carpet and Rug Institute, Inc. Certification Date: 2/5/2018 Expiration Date: 12/31/2025





**GLP100044** 

This product complies with California DPH Section 01350 Version 1.2

A USGBC® recognized third party certification program for LEED v4.1 **EQ Credit Low-Emitting Materials.** 



#0754