

# GREEN LABEL PLUS

## INDOOR AIR QUALITY TESTING PROGRAM

THIS CERTIFIES THAT

### Kraus Flooring

65 Northfield Dr, Waterloo Ontario N2J 4J4, Canada

HAS MET THE REQUIREMENTS OF THE CARPET AND RUG  
INSTITUTE'S GREEN LABEL PLUS PROGRAM FOR CATEGORY:

### A-2 Pressure Sensitive

Adhesive Applied in Mass Per Surface Area: 8.41 g of product per 0.361 m<sup>2</sup>

Private Office Range of Total VOCs: 0.5 mg/m<sup>3</sup> or less

School Classroom Range of Total VOCs: 0.5 mg/m<sup>3</sup> or less

Type of Product: Single Part Wet Adhesive

Description: KPA-31, KPA-51 and KPA99



THE CARPET AND RUG INSTITUTE  
100 S HAMILTON STREET  
DALTON, GA 30720-4612  
UNITED STATES



## GLP100208

This product category complies  
with the concentration limits  
specified in California DPH Section  
01350 Version 1.2.

A USGBC® recognized third party  
certification program for LEED v4.1  
EQ Credit Low-Emitting Materials.



Russ DeLozier, President  
The Carpet and Rug Institute, Inc.

Certification Date: 3/31/2020  
Expiration Date: 12/31/2025

To view all GLP-Certified products visit <https://carpet-rug.org/glpproducts>

Page 1 of 1