

GREEN LABEL PLUS

INDOOR AIR QUALITY TESTING PROGRAM

THIS CERTIFIES THAT

Gerflor Canada Flooring

1305 Rue Marie-Victorin, Saint-Bruno Quebec J3V 6B7, Canada

HAS MET THE REQUIREMENTS OF THE CARPET AND RUG INSTITUTE'S GREEN LABEL PLUS PROGRAM FOR CATEGORY:

A-3 Floor Adhesive for Vinyl Backs

Adhesive Applied in Mass Per Surface Area: 12.31 g of product per 0.0361 m²

Private Office Range of Total VOCs: 0.5 mg/m³ or less

School Classroom Range of Total VOCs: 0.5 mg/m³ or less

Type of Product: Single Part Wet Adhesive

Description: Gerfix 313, Gerfix 125



THE CARPET AND RUG INSTITUTE
100 S HAMILTON STREET
DALTON, GA 30720-4612
UNITED STATES



GLP100303

This product complies with
California DPH Section 01350
Version 1.2

A USGBC® recognized third party
certification program for LEED v4.1
EQ Credit Low-Emitting Materials.



Russ DeLozier, President
The Carpet and Rug Institute, Inc.

Certification Date: 7/19/2021
Expiration Date: 6/29/2025

To view all GLP-Certified products visit <https://carpet-rug.org/glpproducts>