

GREEN LABEL PLUS

INDOOR AIR QUALITY TESTING PROGRAM

THIS CERTIFIES THAT

Signature Flooring

PFLC, LLC

2222 South Hamilton St, Dalton, GA 30721, United States

HAS MET THE REQUIREMENTS OF THE CARPET AND RUG INSTITUTE'S GREEN LABEL PLUS PROGRAM FOR CATEGORY:

A-20 Water-Based SBR/Latex Adhesive

Adhesive Applied in Mass Per Surface Area: 16.07 g of product per 0.0361 m²

Private Office Range of Total VOCs: 0.5 mg/m³ or less

School Classroom Range of Total VOCs: 0.5 mg/m³ or less

Type of Product: Single Part Wet Adhesive

Description: Signature 2800 Ultimate Adhesive



THE CARPET AND RUG INSTITUTE

100 S HAMILTON STREET

DALTON, GA 30720-4612

UNITED STATES



GLP101075



This product category complies with the concentration limits specified in California DPH Section 01350 Version 1.2.

USGBC® recognizes CRI's Green Label Plus certification for LEED (v4.1 and v5) EQ Credit Low-Emitting Materials.

Russ DeLozier, President
The Carpet and Rug Institute, Inc.

Certification Date: 3/6/2024
Expiration Date: 12/31/2026

To view all GLP-Certified products visit <https://carpet-rug.org/glpproducts>