

# GREEN LABEL PLUS

## INDOOR AIR QUALITY TESTING PROGRAM

THIS CERTIFIES THAT

### Lighthouse Adhesives LLC

4284 S Dixie Hwy, Resaca, GA 30735, United States

HAS MET THE REQUIREMENTS OF THE CARPET AND RUG  
INSTITUTE'S GREEN LABEL PLUS PROGRAM FOR CATEGORY:

### A-2 Pressure Sensitive

Adhesive Applied in Mass Per Surface Area: 5.59 g of product per 0.0361 m<sup>2</sup>

Private Office Range of Total VOCs: 0.5 mg/m<sup>3</sup> or less

School Classroom Range of Total VOCs: 0.5 mg/m<sup>3</sup> or less

Type of Product: Single Part Wet Adhesive

Description: UN1 GLU PSA and UN1 GLU ULTRA



THE CARPET AND RUG INSTITUTE  
100 S HAMILTON STREET  
DALTON, GA 30720-4612  
UNITED STATES



**GLP101080**



This product category complies with  
the concentration limits specified in  
California DPH Section  
01350 Version 1.2.

USGBC® recognizes CRI's Green Label  
Plus certification for LEED (v4.1 and v5)  
EQ Credit Low-Emitting Materials.

Russ DeLozier, President  
The Carpet and Rug Institute, Inc.

Certification Date: 3/22/2024  
Expiration Date: 6/29/2026

To view all GLP-Certified products visit <https://carpet-rug.org/glpproducts>  
Page 1 of 1