

# GREEN LABEL PLUS

## INDOOR AIR QUALITY TESTING PROGRAM

THIS CERTIFIES THAT

**Lonseal, Inc.**

928 E 238th St, Carson, CA 90745, United States

HAS MET THE REQUIREMENTS OF THE CARPET AND RUG  
INSTITUTE'S GREEN LABEL PLUS PROGRAM FOR CATEGORY:

### A-13 Rubber Flooring Adhesive

Adhesive Applied in Mass Per Surface Area: 9.95 g of product per 0.0361 m<sup>2</sup>

Private Office Range of Total VOCs: 0.5 mg/m<sup>3</sup> or less

School Classroom Range of Total VOCs: 0.5 mg/m<sup>3</sup> or less

Type of Product: Two Part Wet Adhesive

Description: Lonseal #650, Two-Component, Solvent-Free Epoxy Adhesive.



THE CARPET AND RUG INSTITUTE  
100 S HAMILTON STREET  
DALTON, GA 30720-4612  
UNITED STATES



**GLP59909**

This product category complies  
with the concentration limits  
specified in California DPH Section  
01350 Version 1.2.

A USGBC® recognized third party  
certification program for LEED v4.1  
EQ Credit Low-Emitting Materials.



Russ DeLozier, President  
The Carpet and Rug Institute, Inc.

Certification Date: 2/28/2014  
Expiration Date: 9/27/2025

To view all GLP-Certified products visit <https://carpet-rug.org/glpproducts>