GREEN LABEL PLUS

INDOOR AIR QUALITY TESTING PROGRAM

THIS CERTIFIES THAT Tarkett USA, Inc.

30000 Aurora Rd, Solon, Ohio 44139, United States

HAS MET THE REQUIREMENTS OF THE CARPET AND RUG INSTITUTE'S GREEN LABEL PLUS PROGRAM FOR CATEGORY:

A-4 Latex Seam Adhesive

Adhesive Applied in Mass Per Surface Area: 2.81 g of product per 0.292 m²

Private Office Range of Total VOCs: 0.5 mg/m³ or less School Classroom Range of Total VOCs: 0.5 mg/m³ or less

Type of Product: Single Part Wet Adhesive

Description: C-XL Universal Seam Sealer

Russ DeLozier, President The Carpet and Rug Institute, Inc. Certification Date: 7/25/2008 Expiration Date: 12/31/2025





GLP60151

This product category complies with the concentration limits specified in California DPH Section 01350 Version 1.2.

A USGBC® recognized third party certification program for LEED v4.1 **EQ Credit Low-Emitting Materials.**



To view all GLP-Certified products visit https://carpet-rug.org/glpproducts Page 1 of 1