

GREEN LABEL PLUS

INDOOR AIR QUALITY TESTING PROGRAM

THIS CERTIFIES THAT

Southwind Building Products

601 Callahan Rd SE, Dalton, GA 30721, United States

HAS MET THE REQUIREMENTS OF THE CARPET AND RUG INSTITUTE'S GREEN LABEL PLUS PROGRAM FOR CATEGORY:

CN13 Nylon with PVC Backing

Private Office Range of Total VOCs: 0.5 mg/m³ or less
School Classroom Range of Total VOCs: 0.5 mg/m³ or less
Type of Product: Modular Tile

Description: Pre-dyed Nylon with PVC Carpet tile

Russ DeLozier, President
The Carpet and Rug Institute, Inc.

Certification Date: 8/22/2022
Expiration Date: 12/31/2026

To view all GLP-Certified products visit <https://carpet-rug.org/glpproducts>
Page 1 of 1



THE CARPET AND RUG INSTITUTE
100 S HAMILTON STREET
DALTON, GA 30720-4612
UNITED STATES



GLP100713



This product category complies with the concentration limits specified in California DPH Section 01350 Version 1.2.

USGBC® recognizes CRI's Green Label Plus certification for LEED (v4.1 and v5) EQ Credit Low-Emitting Materials.