

GREEN LABEL PLUS

INDOOR AIR QUALITY TESTING PROGRAM

THIS CERTIFIES THAT

Duguza Pty Ltd ATF Zinkwazi

House & Haven Australia, PO Box 502, Mount Gravatt Qld Australia 4122, Australia

HAS MET THE REQUIREMENTS OF THE CARPET AND RUG
INSTITUTE'S GREEN LABEL PLUS PROGRAM FOR CATEGORY:

CN14 Nylon with SB Latex Backing

Private Office Range of Total VOCs: 0.5 mg/m³ or less

School Classroom Range of Total VOCs: 0.5 mg/m³ or less

Type of Product: Broadloom

Description: * ODESSA SDN - 1/5th Gauge scroll loop * ZEST SDN - 1/5th Gauge scroll loop * APOLLO
SDN - 10th Gauge cut pile



THE CARPET AND RUG INSTITUTE

100 S HAMILTON STREET

DALTON, GA 30720-4612

UNITED STATES



GLP101090



This product category complies with
the concentration limits specified in
California DPH Section
01350 Version 1.2.

USGBC® recognizes CRI's Green Label
Plus certification for LEED (v4.1 and v5)
EQ Credit Low-Emitting Materials.

Russ DeLozier, President
The Carpet and Rug Institute, Inc.

Certification Date: 4/25/2024
Expiration Date: 6/30/2027

To view all GLP-Certified products visit <https://carpet-rug.org/glpproducts>
Page 1 of 1