

GREEN LABEL PLUS

INDOOR AIR QUALITY TESTING PROGRAM

THIS CERTIFIES THAT

Bloq

Bloq Betap Tufting

De Blokmat 29, Genemuiden, 8281 JH, The Netherlands

HAS MET THE REQUIREMENTS OF THE CARPET AND RUG
INSTITUTE'S GREEN LABEL PLUS PROGRAM FOR CATEGORY:

CO3 Polypropylene with Bitumen Backing

Private Office Range of Total VOCs: 0.5 mg/m³ or less

School Classroom Range of Total VOCs: 0.5 mg/m³ or less

Type of Product: Modular Tile



THE CARPET AND RUG INSTITUTE

100 S HAMILTON STREET

DALTON, GA 30720-4612

UNITED STATES



GLP101150



ANSI National Accreditation Board

ACCREDITED

ISO/IEC 17065

PRODUCT CERTIFICATION
BODY

#0754

This product category complies with
the concentration limits specified in
California DPH Section
01350 Version 1.2.

USGBC® recognizes CRI's Green Label
Plus certification for LEED (v4.1 and v5)
EQ Credit Low-Emitting Materials.

Russ DeLozier, President
The Carpet and Rug Institute, Inc.

Certification Date: 11/5/2024
Expiration Date: 12/31/2026

To view all GLP-Certified products visit <https://carpet-rug.org/glpproducts>

Page 1 of 1