

GREEN LABEL PLUS

INDOOR AIR QUALITY TESTING PROGRAM

THIS CERTIFIES THAT

Dunlop Flooring Australia

183 - 187 Newton Road, Wetherill Park, Sydney NSW 2164, Australia

HAS MET THE REQUIREMENTS OF THE CARPET AND RUG INSTITUTE'S GREEN LABEL PLUS PROGRAM FOR CATEGORY:

CC-2 Bonded Polyurethane

Private Office Range of Total VOCs: 0.5 mg/m³ or less

School Classroom Range of Total VOCs: 0.5 mg/m³ or less



THE CARPET AND RUG INSTITUTE
100 S HAMILTON STREET
DALTON, GA 30720-4612
UNITED STATES



GLP057



ANSI National Accreditation Board

ACCREDITED

ISO/IEC 17065

PRODUCT CERTIFICATION
BODY

#0754

This product category complies with the concentration limits specified in California DPH Section 01350 Version 1.2.

USGBC® recognizes CRI's Green Label Plus certification for LEED (v4.1 and v5) EQ Credit Low-Emitting Materials.

Russ DeLozier, President
The Carpet and Rug Institute, Inc.

Certification Date: 5/18/2017
Expiration Date: 3/31/2027

To view all GLP-Certified products visit <https://carpet-rug.org/glpproducts>
Page 1 of 1