

GREEN LABEL PLUS

INDOOR AIR QUALITY TESTING PROGRAM

THIS CERTIFIES THAT

Technoflex

922 Jacques-Pashini, Bois-des-Filion Quebec J6Z 4W4, Canada

HAS MET THE REQUIREMENTS OF THE CARPET AND RUG
INSTITUTE'S GREEN LABEL PLUS PROGRAM FOR CATEGORY:

CC-10 Rubber

Private Office Range of Total VOCs: 0.5 mg/m³ or less

School Classroom Range of Total VOCs: 0.5 mg/m³ or less

Description: Technofloor Acoustic



THE CARPET AND RUG INSTITUTE

100 S HAMILTON STREET

DALTON, GA 30720-4612

UNITED STATES



GLP826

This product category complies
with the concentration limits
specified in California DPH Section
01350 Version 1.2.

A USGBC® recognized third party
certification program for LEED v4.1
EQ Credit Low-Emitting Materials.



Russ DeLozier, President
The Carpet and Rug Institute, Inc.

Certification Date: 6/8/2017
Expiration Date: 3/31/2026

To view all GLP-Certified products visit <https://carpet-rug.org/glpproducts>

Page 1 of 1